

No. 10175300-INC 19-3210

**Issued to:**

GE Renewable Energy  
St. Leonards Building, Harry Kerr Drive  
Stafford ST16 1WT  
United Kingdom

**For the server product:**

MiCOM P40 Agile  
P545 Line Differential Protection  
Software version: 92A  
Hardware version: M

The server product has not been shown to be non-conforming to:

## IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL<sup>2</sup> 1.2.4 with product's protocol, model and technical issue implementation conformance statements: "MiCOM P40 Agile Px4x PICS Protocol Implementation Conformance - IEC 61850 Edition 2, Px4x-PC2-EN-E", "MiCOM P40 Agile P545 MICS Model Implementation Conformance - IEC 61850 Edition 2, P545-MC2-EN-3" and "MiCOM P40 Agile P543, P545 TICS Tissues conformance statement, P54x-TC2-EN-3" and the extra information for testing: "MiCOM P40 Agile P543, P545 PIXIT Protocol Implementation eXtra Information for Testing - IEC 61850 Edition 2, P54x-PX2-EN-3".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (24/26)	9a GOOSE Publish (12/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (14/14)
4 Setting Group Selection (4/4)	12a Direct Control (8/18)
5 Unbuffered Reporting (19/21)	12b SBO Control (14/27)
6 Buffered Reporting (26/30)	12c Enhanced Direct Control (10/20)
	12d Enhanced SBO Control (15/28)
	13 Time Synchronization (4/7)
	14 File Transfer (7/8)

This certificate includes a summary of the test results as carried out at GE Renewable Energy in United Kingdom with UniGrid SA Simulator 1.6.7 with test suite 1.0.24 and UniCA 61850 Analyzer 5.34.01. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10175300-INC 19-3209 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by GE Renewable Energy. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, December 17, 2019



**N.A. Heijker**  
Business Leader  
Interoperability of Smart Power Systems

**Issued by:**



**DNV-GL**

DNV KEMA is now DNV GL



**R. Schimmel**  
Verification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System

<sup>2</sup> TPCL - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.4

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv9, sSrv10, sSrv12, sSrv13, sSrvN1e, sSrvN1f, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp13, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr13
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11	sGop1, sGop5, sGop6, sGop7, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4, sGos6b
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl7, sCtl13, sCtl15, sCtl16
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl6, sCtl7, sCtl15, sCtl16, sCtl27
12c: Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl7, sCtl13, sCtl14, sCtl15, sCtl16, sCtl26
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl6, sCtl7, sCtl15, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTm3
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	sFt2c, sFtN1c

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version:

- MiCOM P40 Agile P543 Line Differential Relay
- MiCOM P40 Agile P443 MiCOMho Distance Relay