

IEC 61850 Conformance Certificate Level B¹

Issued to:
ABB Power Grids Sweden AB
GA Products
S-721 59 Västerås
Sweden

For the server product:
REC670 Bay Control
Product version: 2.2.4
Firmware version: 2.2.10.9
S/N: T1749268

Issued by: ABB Power Grids Switzerland Ltd, SVC Baden

The server product has not shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.3a, the product's protocol, model and technical issue implementation conformance statements: "1MRG037791 ABB 650 & 670 series version 2.2.4 Ed1- PICS", "1MRG037797 ABB 670 & 650 series version 2.2.4 Ed1 - MICS", "1MRG037793 ABB 650 & 670 series version 2.2.4 Ed1 - TICS" and the extra information for testing: "1MRG037792 ABB 650 & 670 series version 2.2.4 Ed1 - PIXIT"

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):


1	Basic Exchange (21/25)	9a	GOOSE Publish (9/12)
2	Data Sets (3/6)	9b	GOOSE Subscribe (11/11)
3	Substitution (4/4)	12a	Direct Control (7/11)
4	Setting Group Selection (3/3)	12d	Enhanced SBO Control (14/19)
5	Unbuffered Reporting (15/18)	13	Time Synchronization (5/5)
6	Buffered Reporting (23/27)	14	File Transfer (6/7)

This Certificate includes a summary of the test results as carried out at the SVC Baden in Switzerland with UniCasim 61850 version 4.31.02 and test suite SVC2020v1 and UniCA Analyzer 5.34.01. This document has been issued for information purposes only, and the original paper copy of the SVC Baden report: No. 1KHL050129 will prevail. The test has been carried out on one single specimen of the product as referred above and submitted to SVC Baden by ABB AB, GA Products. The manufacturer's production process has not been assessed. This certificate does not imply that SVC Baden has approved any product other than the specimen tested.

Baden, 2020-04-09



S. Meier
Certification Manager



C. Zehnder
Test engineer

1 Level B - Tester with ISO 9001 Quality System

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

Page 1/2

Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version 3.3a

Conformance Block	Mandatory	Conditional
1 Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	AssN3, Srv6, Srv7, Srv8, Srv12 SrvN1e, SrvN1f, SrvN3
2 Data Sets	Dset1, Dset10a, DsetN1ae	
3 Substitution	Sub1, Sub2, Sub3, SubN1	
4 Setting Group Selection	Sg1, SgN1a, Sg3	
5 Unbuffered Reports	Rp1, Rp2, Rp3, Rp4, Rp9, RpN1, RpN2, RpN3, RpN4, RpN8	Rp5, Rp8, Rp10, Rp11, Rp12
6 Buffered Reports	Br1, Br2, Br3, Br4, Br9, Br20, Br21, Br22, Br25, Br26, Br27, Br28 BrN1, BrN2, BrN3, BrN4, BrN5, BrN8	Br5, Br8, Br10, Br11, Br12
9a GOOSE publish	Gop2, Gop3, Gop4, Gop9, Gop10a	Gop1, Gop7, Gop10b, GopN2
9b GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b, Gos4
12a Direct Control	CtiN3, DOns1	Cti2, Cti7, CtiN10, CtiN11 DOns3
12d Enhanced SBO control	CtiN1, CtiN2, CtiN3, CtiN4, CtiN9 SBOes1, SBOes2, SBOes3	Cti2, Cti3, Cti7, CtiN6, CtiN10, CtiN11
13 Time Synchronization	Tm1, Tm2,	Tm3, TmN1, TmN2
14 File Transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c

All configuration file and data model tests have been successfully performed for the product variants using the same hardware and software version:

- REB650 Busbar Protection
- REC650 Bay Control
- RED650 Line Differential Protection
- REL650 Line Distance Protection
- REQ650 Breaker Protection
- RET650 Transformer Protection
- REB670 Busbar Protection
- RED670 Line Differential Protection
- REG670 Generator Protection
- REL670 Line Distance Protection
- RES670 Phasor Measurement
- RET670 Transformer Protection

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

Page 2/2