

No. 10261725-INC 20-3151rev1

Issued to:

TOSHIBA Energy Systems &
Solutions Corporation
Power Systems Protection and Control Dept.
Fuchu Complex, 1 TOSHIBA-Cho
Fuchu-shi, Tokyo 183-8511
Japan

For the server product:

GRH200
High-Impedance Differential Protection
IEC 61850 Software version: G2M85002A
Main Software version: GS2RHIM13003
Hardware: GRH200-91-213-00-4L-30-110
S/N: VNT1188 FM 0001-2

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev5 with product's protocol, model and technical issue implementation conformance statements: "IEC61850 ACSI Conformance Statement for G2 series IED, 6F2S1874, Ver. 0.6", "Model implementation conformance Statement (MICS) of the IEC 61850 Ed.2 GRH200, 6F2S1972, Ver. 0.0" and "Tissues conformance statement (TICS) of the IEC 61850 Ed.2 communication interface in G2 series IED, 6F2S1920, Ver. 0.2" and the extra information for testing: "Protocol implementation extra information for testing (PIXIT) of the IEC 61850 communication interface in G2 series IED, 6F2S1875, Ver. 0.12".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (24/28)	12a Direct Control (6/17)
2 Data Sets (4/7)	12b SBO Control (12/26)
4 Setting Group Selection (4/4)	12c Enhanced Direct Control (8/19)
5 Unbuffered Reporting (21/22)	12d Enhanced SBO Control (14/27)
6 Buffered Reporting (29/32)	13 Time Synchronization (4/7)
9a GOOSE Publish (11/13)	14 File Transfer (5/8)
9b GOOSE Subscribe (17/18)	15 Service Tracking (1/17)

This certificate includes a summary of the test results as carried out at DNV GL in The Netherlands with UniGrid SA Simulator 1.7.1 with test suite 1.1.0 and UniCA 61850 Analyzer 6.40.05. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10261725-INC 20-3150 rev 1 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Toshiba. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, December 2, 2020



N.A. Heijker
Business Leader
Interoperability of Smart Power Systems

Issued by:



DNV KEMA is now DNV GL



R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv9, sSrv10, sSrv12, sSrvN1e, sSrvN1f, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr15
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop6, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl7, sCtl16
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl4, sCtl7, sCtl16
12c: Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl7, sCtl14, sCtl16, sCtl26
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl7, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTm3
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	
15: Service tracking		sTrk7