



# IEC 61850 Certificate Level A<sup>1</sup>

Page 1/2

No. 30920566-Consulting 10-0379

Issued to:  
ABB AB  
SA Products  
S-721 59 Västerås  
Sweden

For the product:  
REC670  
Software version 1.5.0.1  
Hardware version 1MRK001535-19



The product has not shown to be non-conforming to:  
**IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "IED670\_series\_ver\_1.2\_IEC61850\_PICS", "IED\_670\_series\_ver\_1.2\_IEC\_61850\_MICS", "IED670\_series\_ver\_1.2\_IEC61850\_TICS" and product's extra information for testing: "IED670\_series\_ver\_1.2\_IEC61850\_PIXIT".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2):

1 Basic Exchange (19/24)	9a GOOSE Publish (6/12)
2 Data Sets (3/6)	9b GOOSE Subscribe (9/10)
3 Substitution (4/4)	12a Direct Control (5/11)
4 Setting Group Selection (2/3)	12d Enhanced SBO Control (11/19)
5 Unbuffered Reporting (12/18)	13 Time Synchronization (3/4)
6 Buffered Reporting (15/20)	14 File Transfer (6/7)

This Certificate includes a summary of the test results as carried out at KEMA in The Netherlands with UniCAsim 61850 version 3.19.02 with test suite 3.19.02 and UniCA 61850 analyzer 4.20.05. The test is based on the UCA International Users Group Device Test Procedures version 2.2. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30920566-Consulting 10-0378 will prevail.

The test has been carried out on one single specimen of the products as referred above and submitted to KEMA by ABB AB. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, February 17, 2010

W. Strabbing  
Manager Intelligent Networks and Communication

S.J.T. Mulder  
Senior Testengineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
3: Substitution	Sub1, Sub2, Sub3, SubN1	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10 RpN1, RpN2, RpN3, RpN4	Rp5, Rp8
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CtlN3, CtlN8, DOns1, DOns3	CtlN11
12d: Enhanced SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9 SBOes1, SBOes2, SBOes3	Ctl7, CtlN11
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c

All configuration file and data model tests have been successfully performed for the product variants using the same hardware and software version: REB670, RED670, REG670, REL670, RET670