

IEC 61850 Certificate Level A¹

Page 1/2

Issued to:

TOSHIBA Corporation Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Tokyo, 183-8511 Japan

No. 30102109-Consulting 10-1617

For the product: **GRD130**

Hardware: GRD130

Main software: GSPDM1-03-A IEC61850 communication firmware:

GPM850-01-E

Issued by:



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "IEC 61850 ACSI conformance statement GRD130, version 0.0", "IEC 61850 Tissues Conformance Statement (TICS) of the IEC 61850 interface in the GRD130, version 0.0" and product's extra information for testing: "Protocol implementation extra information for testing (PIXIT) of the IEC 61850 interface in the GRD130, version 0.1"

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2):

- Basic Exchange (17/24)
- 2 Data Sets (3/6)
- Setting Group Selection (2/3)
- Unbuffered Reporting (14/18) 5
 - Buffered Reporting (16/20)

- 9a GOOSE Publish (7/12)
- GOOSE Subscribe (9/10)
- 12c Enhanced Direct Control (4/13)
- 13 Time Synchronization (5/5) 14 File Transfer (4/7)

This Certificate includes a summary of the test results as carried out at TOSHIBA Corporation, Japan with UniCAsim 61850 version 3.21.03 with test suite 3.21.00 and UniCA 61850 analyzer 4.21.02. The test is based on the UCA International Users Group Device Test Procedures version 2.2. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30102109-Consulting 10-1619 will prevail.

The test has been carried out on one single specimen of the products as referred above and submitted to KEMA by TOSHIBA. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, 23 July

W. Strabbing

Manager Intelligent Networks and Communication

R.S. Massink Junior Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5	Srv6, Srv7, Srv8
	Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10	Rp5, Rp8, RpN5, RpN6
	RpN1, RpN2, RpN3, RpN4	
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12	Br5, Br10, BrN6
	BrN1, BrN2, BrN3, BrN4, BrN5	
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop6, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12c: Enhanced Direct Control	CltN3, CtlN8, DOes2, DOes5	
13: Time sync	Tm1, Tm2, TmN1	TmN2, Tm3
14: File transfer	Ft1, Ft2ab, FtN1ab	Ft4