



# IEC 61850 Certificate Level A<sup>1</sup>

No. 30913327-Consulting 10-0712

Issued to:  
ABB Switzerland Ltd  
High Voltage Technology  
Brown Boveri-Strasse 5  
CH-8050 zurich  
Switzerland

For the 92LE publisher:  
CP-MUP merging unit for protection  
Hardware version AD  
Firmware version 1.0.1.0  
Supporting:  
3 phase voltage and current  
Neutral is calculated



**The product has not shown to be non-conforming to:**  
**IEC 61850-6, 7-2 and 9-2**  
**Communication networks and systems in substations**

The conformance test has been performed according to IEC 61850-10 with 92LE publisher's protocol implementation conformance statement: "CP-MUP PICS PIXIT, 1HC0071175 version AB" and extra information for testing: "CP-MUP PICS PIXIT, 1HC0071175 version AB".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCAIUG Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2" (9-2LE), version 1.1):

11a Sampled Value publish (13/17)	50 Hz with 80 samples per cycle
11a Sampled Value publish (13/17)	60 Hz with 80 samples per cycle

This Certificate includes a summary of the test results as carried out at KEMA in the Netherlands with UniCA 61850 Analyzer 61850 version 4.21.02. The test is based on the UCAIUG "Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2" (9-2LE), version 1.1". This document has been issued for information purposes only, and the original paper copy of the test report: No. 30913327-Consulting 10-0713 will prevail.

The test has been carried out on one single specimen of the client system as referred above and submitted to KEMA by ABB. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, 24 March 2010

  
W. Strabbing  
Manager Intelligent Network and Communications

  
Richard Schimmel  
Senior Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCAIUG "Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2" (9-2LE), version 1.1"

<b>Conformance Block</b>	<b>Mandatory</b>	<b>Conditional</b>
Configuration	Cnf1, Cnf2, Cnf3, Cnf4, Cnf5, Cnf6, Cnf7, Cnf8	
11a Sampled Value Publishing 50 Hz, 80 samples/cycle	Svp1, Svp2, Svp3, Svp6, Svp10, Svp11, Svp14, Svp15	Svp4, Svp7, Svp8, Svp16, Svp17
11a Sampled Value Publishing 60Hz, 80 samples/cycle	Svp1, Svp2, Svp3, Svp6, Svp10, Svp11, Svp14, Svp15	Svp4, Svp7, Svp8, Svp16, Svp17