



# IEC 61850 Certificate Level A<sup>1</sup>

Page 1/2

No. 13-048102-01

Issued to:  
VITZRO SYS.  
233-3 Seongsu 2-ga, 1-dong, Seongdong-gu,  
Seoul, Korea

For the client system:  
VITZROSYS 61850 Smart Module  
Software:1.0  
Hardware: HP Compaq dc7800 with  
Windows 7

Issued by: **KOREA TESTING LABORATORY**

**The client system has not shown to be non-conforming to:  
IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1  
Communication networks and systems in substations**

The conformance test has been performed according to IEC 61850-10 and UCA IUG Conformance Test Procedures for Client System with IEC 61850-8-1 interface, revision 1.1 with TPCL<sup>2</sup> version 1.2 with client system's protocol, model and technical issue implementation conformance statements: "Smart Module-PICS-V1.0.0", " Smart Module-MICS-V1.0.0", "Smart Module-TICS-V1.0.0" and product's extra information for testing: "Smart Module-PIXIT-V1.0.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

|                                   |                                   |
|-----------------------------------|-----------------------------------|
| 1 Basic Exchange (21/22)          | 12a Direct Control (6/7)          |
| 2 Data Sets (7/9)                 | 12b SBO Control (8/9)             |
| 2+ Data Set Definition (4/4)      | 12c Enhanced Direct Control (6/7) |
| 4 Setting Group Selection (4/4)   | 12d Enhanced SBO Control (8/9)    |
| 4+ Setting Group Definition (2/2) | 13 Time Synchronization (3/4)     |
| 5 Unbuffered Reporting (16/18)    | 14 File Transfer (6/8)            |
| 6 Buffered Reporting (20/22)      |                                   |

This certificate includes a summary of the test results as carried out at KTL in the Republic of Korea with IEC 61850 Virtual Server with test suite IEC 61850 Client Conformance Verifier1.0 and KEPSCO ANALYZER 1.0. This document has been issued for information purposes only, and the original paper copy of KTL report: No. 13-048102-01 will prevail.

The test has been carried out on one single specimen of the client system as referred above and submitted to KTL by VITZRO SYS. The manufacturer's production process has not been assessed. This attestation does not imply that KTL has approved any product other than the specimen tested.

Seoul, Nov. 26, 2013

Jin Yong KIM  
Test Engineer

Jong Geol YOO  
Director of Digital Convergence Technology Center

1 Level A - Independent Test lab with accredited ISO/IEC 17025 Quality System  
2 TPCL – test procedure change list



Applicable Test Procedures from the UCA IUG Conformance Test Procedures for Client System with IEC 61850-8-1 interface, revision 1.1 with TPCL version 1.2

| Conformance Block            | Mandatory  | Conditional   |
|------------------------------|--|---|
| 1: Basic Exchange            | cAss1, cAss2, cAss3, cAss4, cAssN1, cAssN4, cAssN5, cAssN6                           | cAssN7<br>cSrv1, cSrv2, cSrv3, cSrv4, cSrv5, cSrv6, cSrv7, cSrvN1, cSrvN3, cSrvN4, cSrvN5, cSrvN6 |
| 2: Data Sets                 |  | cDs1, cDs2, cDs3, cDs5, cDsN1a, cDsN1b, cDsN2   |
| 2+: Data Set Definition      | cDs6, cDsN4  | cDs7, cDsN5   |
| 4 Setting Group Selection    | cSg2, cSgN1  | cSg1, cSg3  |
| 4+ Setting Group Definition  | cSg3, cSg4   |   |
| 5: Unbuffered Reporting      | cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRpN2, cRpN3, cRpN7, cRpN8                      | cRp1, cRp2, cRp6, cRp7, cRpN1, cRpN4  |
| 6: Buffered Reporting        | cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr12, cBrN2, cBrN3, cBrN7, cBrN8, cBrN9 | cBr1, cBr2, cBrN1<br>cBr6, cBr7, cBr13, cBrN4   |
| 12a: Direct control          | cCtl4, cCtlN1<br>cDOns1, cDOns2  | cCtl1, cCtl2  |
| 12b: SBO control             | cCtl4, cCtlN1<br>cSBOns1, cSBOns2, cSBOns3   | cCtl1, cCtl2<br>cSBOns4   |
| 12c: Enhanced Direct Control | cCtl4, cCtlN1<br>cDOes1, cDOes2  | cCtl1, cCtl2  |
| 12d: Enhanced SBO control    | cCtl4, cCtlN1,<br>cSBOes1, cSBOes2, cSBOes3  | cCtl1, cCtl2<br>cSBOes4   |
| 13: Time sync                | cTm1   | cTm2, cTmN1   |
| 14: File transfer            | cFt1, cFt2, cFt3, cFtN1, cFtN2   | cFt5  |