



# IEC 61850 Certificate Level A<sup>1</sup>

Ref. No: 2014TS03105

Issued to:

**YOUHO ELECTRIC IND. CO., LTD.**  
**217, HWAHAP-RO, GWANGJEOK-MYEON,**  
**YANGJU-SI, GYEONGGI-DO**  
**Republic of Korea**

For the server product:

**YOUHO GIB PDLU**  
**PD Diagnosis Device Software**  
**Software version 1.0**  
**Hardware : LG15n530**  
**with Window 7**

Issued by:

**Korea Electrotechnology Research Institute**

The server product has not shown to be non-conforming to:

## IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1 Communication networks and systems in substations.

The conformance test has been performed according to IEC 61850-10, UCA International Users Group Device Test Procedures version 2.3 with TPCL<sup>2</sup> 1.7, product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in YOUHO GIB PDLU, v1.0", "Model Implementation Conformance Statement for the IEC 61850 interface in YOUHO GIB PDLU, v1.0", "TISSUES Implementation Conformance Statement for the IEC 61850 interface in YOUHO GIB PDLU, v1.0" and product's extra information for testing "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in YOUHO GIB PDLU, v1.0".

The following IEC 61850 conformance blocks are tested with a positive result (number of relevant and executed test cases / total number of test cases) :

1	Basic Exchange (23/24)	9a	GOOSE Publish (10/13)
2	Data Sets (3/6)	12a	Direct Control (5/12)
4	Setting Group Selection (3/3)	13	Time Synchronization (4/5)
5	Unbuffered Reporting (18/19)	14	File Transfer (4/7)
6	Buffered Reporting (20/21)		

This Certificate includes a summary of the test results as carried out at KERI in Republic of Korea with UniCA 61850 Client simulator version 4.28.04 with test suite version 3.29.02 and UniCA 61850 analyzer version 5.28.03. This document has been issued for information purposes only, and the original paper copy of the KERI report: 2014TS03105 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KERI by YOUHO ELECTRIC IND. CO., LTD. The manufacturer's production process has not been assessed. This Certificate does not imply that KERI has approved any product other than the specimen tested.

Republic of Korea, December 5, 2014

Y. J. Lee  
Executive Director  
Power Apparatus Testing and Evaluation Division

J. I. Jeong  
Technical Manager

<sup>1</sup> Level A – Independent Tester with certified ISO 17025 Quality System

<sup>2</sup> TPCL - Test procedures change list



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL 1.7

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, Srv9, Srv10, SrvN1e, SrvN1f, SrvN2, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
4: Setting Group Selection	Sg1, Sg3, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9, RpN5, RpN6, RpN7
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11, BrN6, BrN7
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7, Gop9, Gop10a	Gop1, Gop6, Gop10b, GopN1
12a: Direct control	CtlN3, CtlN8 DOns1	Ctl2 DOns3
13: Time sync	Tm1, Tm2, TmN1	TmN2
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	