



# IEC 61850 Certificate Level A<sup>1</sup>

No. 74101374-MOC/INC 12-00700

Issued to:  
ALSTOM GRID PROTECTION &  
CONTRÔLE SAS  
25 Rue Didier Daurat  
34170 CASTELNAU-LE-LEZ  
FRANCE

For the product:  
ALSTOM DCS 4.6 Gateway  
GTW Firmware: 6.2.16  
Hardware: Advantech PC  
OS: Windows XP



The product has not shown to be non-conforming to:  
**IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
Communication networks and systems in substations

The conformance test has been performed according to IEC61850-10 with product's protocol, model and technical issue implementation conformance statements "GTW-PICS-C4", "GTW-MICS - C4", "GTW-TICS-A3" and product's extra information for testing "GTW-PIXIT-I2".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2b):

1 Basic Exchange (15/24)	12a Direct Control (4/11)
2 Data Sets (3/6)	12c Enhanced Direct Control (4/13)
5 Unbuffered Reporting (13/18)	12d Enhanced SBO Control (9/19)
6 Buffered Reporting (16/20)	13 Time Synchronization (3/5)

This certificate includes a summary of the test results as carried out at KEMA in the Netherlands with UniCAsim 61850 version 3.23.02 with test suite version 3.24.00 and UniCA 61850 analyzer version 4.24.02. The test is based on the UCA International Users Group Device Test Procedures version 2.2b. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 74101374-MOC/INC 12-00699 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by ALSTOM GRID PROTECTION & CONTRÔLE SAS. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, 13 April, 2012

M. Adriaensen  
Director Management & Operations Consulting

R.S. Massink  
Test engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2b

<b>Conformance Block</b>	<b>Mandatory</b>	<b>Conditional</b>
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv8
2: Data Sets	Dset1, Dset10a, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10 RpN1, RpN2, RpN3, RpN4	Rp5, Rp8, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10, BrN6
12a: Direct control	CtlN3, CtlN8 DOns1, DOns3	
12c: Enhanced Direct Control	CtlN3, CtlN8 DOes2, DOes5	
12d: Enhanced SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9 SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2, TmN1	