



International
Usersgroup

IEC 61850 Certificate Level A¹

Page 1/2

No. 74102092-MOC/INC 12-01970

Issued to:

Siemens A.G., IC SG EA
Protection and Substation Control Systems
Wernerwerkdam 5
D-13623 Berlin
Germany

For the product:

SIPROTEC V4
7ST61
Protection for AC Traction Power Supply
Firmware V04.60
EN100 V04.20

Issued by:



The product has not shown to be non-conforming to:
IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with TPCL² version 1.5, the product's protocol, model and technical issue implementation conformance statements: SIPROTEC 4 Ethernet Module EN100 for IEC 61850 Electrical/Optical 100MBit Interface Manual, Edition June 2012, C53000-G1140-C167-10", "MICS, Mapping family 7STx, Mapping version 1 Revision 0" and the product's extra information for testing: "SIPROTEC Numerical Overhead Contact Line Protection for AC Traction Power Supply 7ST6 V4.6 IEC 61850 PIXIT, C53000-G1140-C373-2".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (19/24)	9a	GOOSE Publish (8/13)
2	Data Sets (3/6)	9b	GOOSE Subscribe (10/11)
2+	Data Set Definition (23/23)	12a	Direct Control (4/12)
4	Setting Group Selection (2/3)	12c	Enhanced Direct Control (4/13)
5	Unbuffered Reporting (17/19)	12d	Enhanced SBO Control (11/19)
6	Buffered Reporting (19/21)	13	Time Synchronization (3/5)
6+	Enhanced Buffered Reporting (12/12)	14	File Transfer (4/7)

This certificate includes a summary of the test results as carried out at Siemens in Germany with UniCA 61850 Client simulator version 3.25.00 with test suite 3.24.02 and UniCA 61850 Analyzer 4.25.01. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 74102092-MOC/INC 12-01969 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by Siemens. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, October 30, 2012


M. Adriaansen
Director Intelligent Networks & Communications


R. Schimmer
Certification Manager

1 Level A - Independent test lab with certified ISO 9000 or ISO 17025 Quality System
2 TPCL - Test procedures change list

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9, Rp11, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11, Br13
6+: Enhanced Buffered reporting	BrE1, BrE2, BrE3, BrE6, BrE7, BrE8, BrE9, BrE10, BrE11	BrE4, BrE5, BrE12
9a: GOOSE Publish	Gop2, Gop3, Gop4, Gop7, Gop10a	Gop1, Gop6, GopN1
9b: GOOSE Subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b
12a: Direct Control	CtiN3, CtiN8, DOs1, DOs3	
12c: Enhanced Direct Control	CtiN3, CtiN8, DOes2, DOes5	
12d: Enhanced SBO Control	Cti3, CtiN1, CtiN2, CtiN3, CtiN4, CtiN9 SBOes1, SBOes2, SBOes3	Cti7, CtiN11
13: Time Sync	Tm1, Tm2, TmN1	
14: File Transfer	Ft1, Ft2ab, Ft4, FtN1ab	

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version: 7ST63.