



# IEC 61850 Certificate Level A<sup>1</sup>

No. 74106066-OPE/INC 14-3323

Issued to:  
Phoenix Contact GmbH & Co. KG  
Flachsmarktstraße 8  
32825 Blomberg  
Germany

For the server product:  
AXL F BK SAS with I/O modules:  
DO16/3 2F, DI16/4 2F, DI16/1 1H,  
DO16/1 1H, DI8/2 110/220 DC 1F,  
DOR4/2 AC/220DC 1F, AI8 1F, AO8 1F,  
RTD4 1H, UTH4 1H.  
Monitoring module  
Firmware version 1.10  
Hardware version 03 (21062013)



Issued by: DNV

**The server product has not been shown to be non-conforming to:**  
**IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
**Communication networks and systems in substations**

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with TPCL<sup>2</sup> version 1.7, the product's protocol, model and technical issue implementation conformance statements: Protocol Implementation Conformance Statement (PICS) for the IEC 61850 interface in AXL F BK SAS with FW version 1.10, Model Implementation Conformance Statement (MICS) for the IEC 61850 interface in AXL F BK SAS with FW version 1.10 and TISSUES Implementation Conformance Statement (TICS) for the IEC 61850 interface in AXL F BK SAS with FW version 1.10 and the extra information for testing: Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in AXL F BK SAS with FW version 1.10.

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (21/24)	12a	Direct Control (3/12)
2	Data Sets (3/6)	13	Time Synchronization (4/5)
5	Unbuffered Reporting (15/19)		
6	Buffered Reporting (18/21)		

This certificate includes a summary of the test results as carried out at Phoenix Contact in Germany with UniCA 61850 Client simulator 4.28.04 with test suite 3.28.00 and UniCA 61850 Analyzer 5.28.03. This document has been issued for information purposes only, and the original paper copy of the DNV KEMA report No. 74106066-OPE/INC 14-3324 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV KEMA by Phoenix Contact. The manufacturer's production process has not been assessed. This attestation does not imply that DNV KEMA has approved any product other than the specimen tested.

Arnhem, November 12, 2014

  
M. Adriaensen  
Director Intelligent Networks & Communication

  
R. Schimmel  
Certification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System

<sup>2</sup> TPCL - Test procedures change list

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this DNV KEMA attestation in any manner whatsoever, including but not limited to dividing it into parts.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.7

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN1f, SrvN2, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11
12a: Direct control	CtiN3, CtiN8 DOns1	
13: Time sync	Tm1, Tm2, TmN1	TmN2