

CENTRAL POWER RESEARCH INSTITUTE

Prof. Sir CV Raman Road, PO Box 8066, Sadashivanagar PO,
BANGALORE – 560 080. I N D I A



IEC 61850 Certificate ^{Level A}



No. ITID/PL/C0049/2010

Issued to:

M/s. Easun Reyrolle Limited,
98, Sipcot Industrial Complex,
Hosur - 635126
India

For the product:

Line Distance Protection Relay- LPRO
Hardware Version: 1.0
Software Version: 1.0
Serial No.: LPRO-4000-100113-02

Issued by: CENTRAL POWER RESEARCH INSTITUTE, India

**The product has not shown to be non-conforming to:
IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations**

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "PICS version 1.00", "MICS version 1.00", "TICS version 1.00" and products extra information for testing: "PIXIT for testing for Easun Reyrolle range of Protection IEDs version 1.00".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases/total number of applicable test cases as defined in the UCA International Users Group Device Test procedures):

1 Basic Exchange (20/20)	6 Buffered Reporting(15/15)
2 Data Sets (3/3)	9ab GOOSE (15/15)
3 Substitution (4/4)	12a Direct Control (5/5)
4 Setting Group Selection (3/3)	14 File Transfer (7/7)
5 UnBuffered Reporting (13/13)	


This Certificate includes a summary of the test results as carried out at CPRI, Bangalore, India with UniCAsim 61850 version 3.21.00 test system running test suit "61850 Conformance Test v3.20.00", and UniCAsim 61850 analyzer version 4.20.01. The test is based on the UCA International Users Group Device Test Procedures version 2.2b. This document has been issued for information purposes only and the original paper copy of the CPRI report No.: ITID/PL/T0049/2010. Dated: June 21, 2010 will prevail.

The tests have been carried out on one single specimen of the products as referred above and submitted to CPRI by M/s. Easun Reyrolle Ltd., Hosur, India. The manufacturer's production process has not been assessed. This Certificate does not imply that CPRI has certified or approved any product other than the specimen tested.

Bangalore, 21 June 2010.


(Mridula Jain)
Test Engineer





(V. Arunachalam)
Additional Director


Report Reference No: ITID/PL/T0049/2010 Dated: June 21, 2010

Page 1 of 2

Applicable Test Cases:

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5, Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN2, SrvN3
2: Data Set	Dset1, Dset10a, DsetN1ae	---
3: Substitution	Sub1, Sub2, Sub3, SubN1	---
4: Setting Group Selection	Sg1, SgN1a	Sg3
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, RpN1, RpN2, RpN3, RpN4	Rp5, RpN5, Rp8
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	---
12a: Direct control	CtIN3, CtIN8 DOns1, DOns3	CtI2
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c, FtN1d


(Mridula Jain)
Test Engineer


(V. Arunachalam)
Additional Director