

CENTRAL POWER RESEARCH INSTITUTE

Prof. Sir CV Raman Road, PO Box 8066, Sadashivanagar PO, BANGALORE – 560 080. I N D I A



IEC 61850 Certificate Level A

AND OF THE PARTY O

No. UARC/PL/C0062/2012

Issued to:

Schneider Electric No.3/86-E, Ambattur Industrial Estate, Ambattur, Chennai-600 058, India A Subsidiary of Schneider Electric 35, Rue Joseph Monier, 92500, Rueil Malmaison, France.

For the product:

Numerical Busbar Protection - Central Unit

Type: MiCOM P741 Hardware Version: K Software Version: 51 Serial No.: 36116638/05/12

Issued by: CENTRAL POWER RESEARCH INSTITUTE, India

The product has not shown to be non-conforming to: IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1 Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with Test Procedures Change List (TPCL) version 1.5, the product's protocol, model and technical issue implementation conformance statements: "PICS version K96", "MICS version K96" and the extra information for testing: "PIXIT version A11".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases/total number of test cases):

- 1 Basic Exchange (17/24)
- 2 Data Sets (3/6)
- 4 Setting Group Selection(2/3)
- 5 UnBuffered Reporting (15/19)
- 6 Buffered Reporting (17/21)
- 9a GOOSE Publish (13/13)
- 9b GOOSE Subscribe(10/11)

- 12a Direct Control (4/12)
- 12b SBO Control (6/15)
- 12c Enhanced Direct Control(4/13)
- 12d Enhanced SBO Control(9/19)
- 13 Time Synchronization (3/5)
- 14 File Transfer(6/7)

This Certificate includes a summary of the test results as carried out at CPRI, Bangalore, India with UniCAsim 61850 version 3.25.02 test system running test suit "61850 Conformance Test v3.24.00" and UniCAsim 61850 analyzer version 4.25.00. This document has been issued for information purposes only and the original paper copy of the CPRI Report No.: UARC/PL/T0062/2012; Dated: 12-Dec-2012 will prevail.

The tests has been carried out on one single specimen of the products as referred above and submitted to CPRI by M/s. Schneider Electric. The manufacturer's production process has not been assessed. This Certificate does not imply that CPRI has certified or approved any product other than the specimen tested.

Bangalore, 12-Dec-2012

(V. Arunachalam) Additional Director



(Pradish M) Test Engineer

Report Reference No: UARC/PL/T0062/2012; Dated: 12-Dec-2012











Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5, Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, SrvN1e
2: Data Sets	Dset1, Dset10a, DsetN1ae	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12, RpN1, RpN2, RpN3, RpN4	Rp5, Rp8, RpN5, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14, BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10, BrN6
9a: GOOSE Publish	Gop2, Gop3, Gop4, Gop7, Gop10a	Gop1, Gop5, Gop6, Gop8, Gop9, Gop10b, GopN1, GopN2
9b: GOOSE Subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b
12a: Direct Control	CtlN3, CtlN8, Dons1, Dons3	
12b: SBO Control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, SBOns2	45
12c: Enhanced Direct Control	CtlN3, CtlN8, DOes2, DOes5	
12d: Enhanced SBO Control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9, Sboes1, SbOes2, SbOes3	
13: Time Synchronization	Tm1, Tm2, TmN1	-202
14: File Transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c

All configuration file and data model tests have been successfully performed for the product variants using the same hardware version "K" and software version "51".

(V. Arunachalam) Additional Director

(Pradish M) Test Engineer

Report Reference No: UARC/PL/T0062/2012; Dated: 12-Dec-2012

