

## IEC 61850 Certificate Level B<sup>1</sup>

Issued to:  
ABB AB  
SA Products  
S\_721 59 Västerås, Sweden

For the product:  
REC670 Bay Control  
Firmware Version: 2.0  
Ordering Nr. 1MRK002814-AE  
Serial Number: T1514032

Issued by: ABB Switzerland Ltd, Power Systems, SVC Baden

The product has not been shown to be non-conforming to:

### IEC 61850-5 Edition 2 Performance class P1(3ms)

The performance test has been performed according to the UCA International Users Group GOOSE performance Test Procedures version 2.5 with product's protocol implementation conformance statements: "1MRG014019, ABB 670 series version 2.0 Ed2 - PICS", and product's extra information for testing: "1MRG014021 ABB 670 series version 2.0 Ed2 - PIXIT".

The test has been carried out on one single specimen of the product as referred above and submitted to SVC Baden by ABB AB, SA Products. The manufacturer's production process has not been assessed. This certificate does not imply that SVC Baden has certified or approved any product other than the specimen tested.

This Certificate summarizes test results as carried out at SVC in Switzerland with *Omicron Test Universe V3.01* and *Nethunter V2.2.33*. This document has been issued for information purposes only, and the original paper copy of the test report: No. 1KHL050079 *Test procedures for GOOSE Performance ABB 670 series 2.0\_Rev2p5* will prevail.

The GOOSE performance has been measured with Boolean and Double Point information's.

Baden 2016-01-06



S. Gerspach  
Responsible Test Manager



C. Zehnder  
Responsible Test Engineer

<sup>1</sup> ISO 9000 certified test lab, allowed to issue UCA® level B

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

1/2

ABB Switzerland Ltd  
Power Systems, System Verification and Validation Center, SVC Baden  
Bruggerstrasser 72, CH-5400 Baden



### GOOSE Performance Measured Results:

Performance class = P1 (3ms)

Goose Performance Benchmark summary results (compensated for scan cycle delays if any)

Test ID	Large dataset	Correlated subscribed	Back-ground	Minimum Transfer time [ms]	Maximum Transfer time [ms]	Average Transfer time [ms]
Gpf1	-	-	-	0.69	0.61	0.54
Gpf2	X	-	-	0.70	0.71	0.62
Gpf3	-	X	-	0.69	0.70	0.57
Gpf4	X	X		0.69	0.70	0.59
Gpf5	-	-	X	0.69	0.70	0.52
Gpf6	X	-	X	0.79	0.80	0.62
Gpf7	-	X	X	0.69	0.70	0.57
Gpf8	X	X	X	0.69	0.80	0.62

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

2/2

ABB Switzerland Ltd

Power Systems, System Verification and Validation Center, SVC Baden  
Bruggerstrasser 72, CH-5400 Baden

