



## IEC 61850 Certificate Level A<sup>1</sup>

Page 1/2 No. 16-050376-01

Issued to: On-line Power System Engineering Co., Ltd. #304, Hyundai I Valley 223-12, SangDaewon-Dong, Jungwon-Gu, Seongnam-City, Gyeonggi-Do, Republic of Korea, 13212 For the client system: OPStudio Electrical Diagnostic and Monitoring System Software version 1.0

Issued by: KOREA TESTING LABORATORY

## The client system has not shown to be non-conforming to: IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

## Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 and UCA IUG Conformance Test Procedures for Client System with IEC 61850-8-1 interface, revision 1.1 with TPCL version 1.2.3 with client system's protocol, model and technical issue implementation conformance statements: "OPStudio\_PICS\_v1.0", "OPStudio\_MICS\_v1.0", "OPStudio\_TICS\_v1.0" and product's extra information for testing: "OPStudio\_PIXIT\_v1.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

| 1Basic Exchange (20/22)2Data Sets (7/9)6Buffered Reporting (20/22) | <ul><li>13 Time Synchronization (3/4)</li><li>14 File Transfer (5/8)</li></ul> |
|--|--|
|  |  |

This certificate includes a summary of the test results as carried out at KTL in the Republic of Korea with IEC 61850 Virtual Server with test suite IEC 61850 Client Conformance Verifier1.0 and KEPCO ANALYZER 1.0. This document has been issued for information purposes only, and the original paper copy of KTL report: No. TR-16-050376-01 will prevail.

Seoul, Sep. 9, 2016

Han

Aa Han Senior Engineer New Industry Technology Center for Electric Power

Seogjin Kim Director New Industry Technology Center for Electric Power

1 Level A - Independent Test lab with accredited ISO/IEC 17025 Quality System 2 TPCL – test procedure change list





Applicable Test Procedures from the UCA IUG Conformance Test Procedures for Client System with IEC 61850-8-1 interface, revision 1.1 with TPCL version 1.2.3

| Conformance Block     | Mandatory  | Conditional  |
|-----------------------|--|--|
| 1: Basic Exchange     | cAss1, cAss2, cAss3, cAss4,  | cAssN7,  |
|                       | cAssN1, cAssN4, cAssN5, cAssN6   | cSrv1, cSrv2, cSrv3, cSrv4, cSrv5,<br>cSrv6, cSrvN1, cSrvN3, cSrvN4,<br>cSrvN5, cSrvN6 |
| 2: Data Sets          |  | cDs1, cDs2, cDs3, cDs5, cDsN1a,<br>cDsN1b, cDsN2                                       |
| 6: Buffered Reporting | cBr3, cBr4, cBr5, cBr8, cBr9, cBr10,<br>cBr11, cBr12, cBrN2, cBrN3, cBrN7,<br>cBrN8, cBrN9 | cBr1, cBr2, cBr6, cBr7, cBr13, cBrN1,<br>cBrN4   |
| 13: Time sync         | cTm1   | cTm2, cTmN1  |
| 14: File transfer     | cFt1, cFt2, cFt3, cFtN1, cFtN2   |  |

