

## IEC 61850 Certificate Level A1

No. 2016PUCA0051

Issued to:

NANJING INTELLIGENT APPARATUS CO., LTD. 52#,East Tianyuan Road,Nanjing, Jiangsu Province,China

For the product:

PA620-L4 Line Current Differential Protection Relay Software Version: V1.00

Issued by: **KEOP**押警

The server product has not been shown to be non-conforming to:

## IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations.

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 3.03, the product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) for PA620-L4 Line Current Differential Protection Relay", "Modeling Implementation Conformance Statement(MICS) for PA620-L4 Line Current Differential Protection Relay", "IEC 61850 Tissues Conformance Statement (TICS) for PA620-L4 Line Current Differential Protection Relay" and the extra information for testing: "Protocol implementation extra information (PIXIT) of the IEC 61850 communication interface in PA620-L4 Line Current Differential Protection Relay".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

- 1 Basic Exchange (22/24)
- 2 Data Sets (3/6)
- 3 Substitution(4/4)
- 4 Setting Group Selection (3/3)
- 4+ Setting Group Definition (7/7)
- 5 Unbuffered Reporting (16/19)

- 6 Buffered Reporting (23/28)
- 12a Direct control (3/11)
- 12d Enhanced SBO Control (11/19)
- 13 Time sync (3/5)
- 14 File transfer (4/7)

This Certificate includes a summary of the test results as carried out at the KETOP Lab's offices in Xuchang, China with UniCAsim 61850 Client Version 4.29.03 with test suite Version 3.31.00 and the UniCA 61850 analyzer Version 5.31.00. This document has been issued for information purposes only, and the original paper copy of the KETOP Lab report: No. JW162407 will prevail.

The test have been carried out on one single specimen of the product as referred above and submitted to KETOP Lab by NANJING INTELLIGENT APPARATUS CO., LTD. The manufacturer's production process has not been assessed. This certificate does not imply that KETOP Lab has approved any product other than the specimen tested.

Xuchang, Dec 30th, 2016

极春

He Chun

Director of PRTC Department

银庆公

Yin Qingwei Test Engineer

Page 1 of 2

This certificate is issued in accordance with the laboratory accreditation requirements of the UCA International Users Group. This certificate shall only be reproduced in full and with the express permission of KETOP lab.

China KETOP Lab (Xuchang KETOP Testing Technology CO.LTD )
National Center For Quality Supervision & Testing of Relay Protection and Automation Equipment

1706#, Xuji Avenue, XuChang, Henan, P.R. China, P.C. 461000 T +86 374 3212841 F +86 374 3212775 www.ketop.cn

<sup>&</sup>lt;sup>1</sup> Level A - Independent Test lab with ISO 17025 Quality System



Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version

<b>Conformance Block</b>	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN4,	AssN3, Srv6, Srv7, Srv8, Srv9,
	AssN5	Srv10, SrvN1e, SrvN1f, SrvN3
	Srv1, Srv2, Srv3, Srv4, Srv5,	
	SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
3: Substitution	Sub1,Sub2,Sub3,SubN1	
4: Setting Group Selection	Sg1, SgN1a	Sg3
4+: Setting Group	Sg2, Sg4	
Definition	SgN1b, SgN2, SgN3, SgN4, SgN5	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp9, Rp15	Rp5, Rp8, Rp11, Rp12, RpN5
	RpN1, RpN2, RpN3, RpN4, RpN8	
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br9, Br15, Br20,	Br5, Br8, Br11, Br12
	Br21, Br22, Br25, Br26, Br27, Br28	
	BrN1, BrN2, BrN3, BrN4, BrN5, BrN8	
12a: Direct control	CtlN3, DOns1	DOns3
12d: Enhanced SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4,	CtlN6,CtlN11
	CtlN9	
	SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2	TmN1
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	