

IEC 61850 Certificate Level A¹

No. 10033472-INC 17-2639

Issued to: Schweitzer Engineering Laboratories 2350 NE Hopkins Court Pullman WA 99163 USA For the client system:

SEL-3530-4 Real-Time Automation Controller Software version: SEL-3530-4-R139-V1-Z001001-D20170628 S/N: 1111670342

The client system has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Client Conformance Test Procedures version 1.0 with TPCL² 1.0_rev3 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) for IEC 61850 for the SEL Real-Time Automation Controllers, Revision 2.0", "Model Implementation Conformance Statement (MICS) for IEC 61850 for the SEL Real-Time Automation Controllers, Revision 2.0" and "TISSUES Implementation Conformance Statement for the IEC 61850 interface SEL RTAC, Revision 2.0" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in SEL-RTAC, Revision 2.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

| 1 2 5 6 | Basic Exchange (12/24) Data Sets (2/10) Unbuffered Reporting (17/23) Buffered Reporting (20/28) | 12a Direct Control (6/9) 12b SBO Control (7/11) 12c Enhanced Direct Control (6/9) 12d Enhanced SBO Control (7/11) 12 Time Complementation (2/4) |
|------------------|--|---|
| | | 13 Time Synchronization (3/4) 14 File Transfer (5/8) |

This certificate includes a summary of the test results as carried out at DNV GL in The Netherlands with UniCA 61850 IED simulator 6.1.36 and UniCA 61850 Analyzer 5.31.00. This document has been issued for information purposes only, and the original paper copy of the DNV GL verification report No. 10033472-INC 17-2638 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Schweitzer Engineering Laboratories. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, September 29, 2017

P. Ci

Business Director Intelligent Networks and Communication

Issued by:





 $^1\,{\rm Level}\,{\rm A}$ - Independent test lab with certified ISO 9001 Quality System $^2\,{\rm TPCL}$ - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.



IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Client Conformance Test Procedures version 1.0 with TPCL 1.0_rev3

| Conformance Block | Mandatory | Conditional |
|------------------------------|---|--------------------------------------|
| 1: Basic Exchange | cAss1, cAss2, cAss3, cAssN1, cAssN4, cAssN5, cAssN6 | cAssN7, cSrv5, cSrv7, cSrvN3, cSrvN5 |
| 2: Data Sets | | cDs3, cDsN1c |
| 5: Unbuffered Reporting | cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRp11, cRp13a, cRp14, cRp15, cRpN2, cRpN5, cRpN6 | cRp2, cRp6, cRp7, cRp16 |
| 6: Buffered Reporting | cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr13a, cBr14, cBr15, cBr30, cBr31, cBrN2, cBrN5, cBrN6, cBrN20 | cBr2, cBr6, cBr7, cBr16 |
| 12a: Direct Control | cCtl4, cCtl5, cDOns1, cDOns2 | cCtl1, cCtl2 |
| 12b: SBO Control | cCtl4, cCtl5, cSBOns1, cSBOns2, cSBOns3 | cCtl1, cCtl2 |
| 12c: Enhanced Direct Control | cCtl4, cCtl5, cDOes1, cDOes2 | cCtl1, cCtl2 |
| 12d: Enhanced SBO Control | cCtl4, cCtl5, cSBOes1, cSBOes2, cSBOes3 | cCtl1, cCtl2 |
| 13: Time Synchronization | cTm1, cTmN1 | cTm2 |
| 14: File Transfer | cFt1, cFt3, cFtN1 | cFt2, cFtN2 |