



IEC 61850 Certificate Level A¹

International Usersgroup

No. 30720588-Consulting 08-0828

Issued to:
Hyundai Heavy Industries Co., Ltd
1, Cheonha-dong
Dong-gu, Ulsan
Korea 682-792

For the product:
HIMAP-BCS Hyundai Intelligent
Measurement and Protective Bay
Controller for digital Substation automation
Hardware 1.0
Software 2.0



The product has not shown to be non-conforming to:
IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) of the IEC 61850 communication interface in HIMAP-BCS, revision 0.2", "Model Implementation Conformance Statement for the IEC 61850 interface in HIMAP-BCS, April 2008", "TISSUES Implementation Conformance Statement for the IEC 61850 interface in HIMAP-BCS, April 2008" and product's extra information for testing: "Protocol implementation extra information for testing (PIXIT) of the IEC 61850 communication interface in HIMAP-BCS, revision 0.2".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v1.1):

1 Basic Exchange (20/23)	9a GOOSE Publish (8/11)
2+ Data Set Definition (25/28)	9b GOOSE Subscribe (9/9)
5 Unbuffered Reporting (13/13)	12a Direct Control (5/11)
6 Buffered Reporting (15/15)	12b SBO Control (7/15)
	13 Time Synchronization (3/4)

This Certificate includes a summary of the test results as carried out at KEMA in the Netherlands with UniCasim 61850 version 3.16.00 with test suite 3.16.07 and UniCA 61850 analyzer 4.17.01. The test is based on the UCA International Users Group Device Test Procedures version 1.1. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30720588-Consulting 08-0829 will prevail.

The test has been carried out on one single specimen of the products as referred above and submitted to KEMA by Hyundai. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, 28 April 2008

W. Strabbing
Manager Intelligent Networks and Communication
1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

M. Flohil
Test engineer

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 1.1

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN2, SrvN3
2: Data Sets	Dset1, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, RpN5, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, BrN6
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7, Gop9	Gop1, Gop6, GopN1
9b: GOOSE subscribe	Gos1, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CtlN3, CtlN8 DOns1, DOns3	Ctl2
12b: SBO control	Ctl3, CtlN1, CtlN2, CtlN4 SBOs1, SBOs2	Ctl2
13: Time sync	Tm1, Tm2, TmN1	