

No. 10122257-INC 18-3158

Issued to:

NARI Technology Co. Ltd.
No.19 Chengxin Avenue
211106 Nanjing
People's Republic of China

For the server product:

NSR-3611 Feeder Protection
Software version: 6.03
Hardware version: R1.30
S/N: 7031 39973 000 184202 0178 000 20138760
10 020

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² 1.2.6 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in NSR-3611, V1.00", "Model Implementation Conformance Statement for the IEC 61850 interface in NSR-3611, V1.00" and "TISSUES Implementation Conformance Statement for the IEC 61850 Ed2 interface in NSR-3611, V1.00" and product's extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in NSR-3611, V1.00".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (18/26)	12a Direct Control (5/18)
2 Data Sets (4/7)	12d Enhanced SBO Control (13/28)
3 Substitution (3/3)	13 Time Synchronization (4/7)
4 Setting Group Selection (4/4)	14 File Transfer (5/8)
4+ Setting Group Definition (12/13)	
5 Unbuffered Reporting (19/21)	
6 Buffered Reporting (28/30)	

This certificate includes a summary of the test results as carried out at NARI in China with UniGrid SA Simulator 1.4.361 with test suite 1.0.55 and UniCA 61850 Analyzer 5.34.02. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10122257-INC 18-3159 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by NARI. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, November 30, 2018


S.J.T. Mulder
Business Leader
Interoperability of Smart Power Systems

Issued by:

DNV-GL
DNV KEMA is now DNV GL


R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv8, sSrv9, sSrvN1f
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
3: Substitution	sSub1, sSub2, sSub3	
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg5, sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp13, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr13, sBr23, sBr24
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl16
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl6, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTm3
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version:

- NSR-378LR Transformer protection
- NSR-3610 Feeder Equipment Protection & Measure – Control Device
- NSR-3620 Capacitor Protection
- NSR-3641 Auto Throw-over Protection
- NSR-3661 Motor Protection
- NSR-3670 Reactor Protection
- NSR-3697 Station Transformer Protection