



IEC 61850 Certificate Level A¹

No. 2018PUCA001

Issued to:

ZHUHAI UNITECH POWER TECHNOLOGY CO.LTD.
No.102,Yinhua Road,Xiangzhou,Zhuhai
City,Guangdong Province,P.R.China

For the product:

UT-0221 Smart prevent mal-operation device
Software Version: V1.00.00.00

Issued by:



The server product has not been shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1 **Communication networks and systems in substations.**

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.2, the product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) for UT-0221 Smart prevent mal-operation device", "Modeling Implementation Conformance Statement(MICS) for UT-0221 Smart prevent mal-operation device", "IEC 61850 Tissues Conformance Statement (TICS) for UT-0221 Smart prevent mal-operation device", and the extra information for testing : "Protocol implementation extra information (PIXIT) of the IEC 61850 communication interface in UT-0221 Smart prevent mal-operation device".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (22/24)	12a Direct control (3/11)
2 Data Sets (3/6)	13 Time sync (4/5)
5 Unbuffered Reporting (17/18)	14 File transfer (4/7)
6 Buffered Reporting (24/27)	

This Certificate includes a summary of the test results as carried out at the KETOP Lab's offices in Xuchang, China with UniCAsim 61850 Client Version 4.29.03 with test suite Version 3.31.00 and the UniCA 61850 analyzer Version 5.31.00. This document has been issued for information purposes only, and the original paper copy of the KETOP Lab report: No. JW180651 will prevail.

The test have been carried out on one single specimen of the product as referred above and submitted to KETOP Lab by ZHUHAI UNITECH POWER TECHNOLOGY CO.LTD. The manufacturer's production process has not been assessed. This certificate does not imply that KETOP Lab has approved any product other than the specimen tested.

Xuchang, Apr 07th, 2018

He Chun
Director of PRTC Department

Liu Desen
Test Engineer

¹ Level A - Independent Test lab with ISO 17025 Quality System

This certificate is issued in accordance with the laboratory accreditation requirements of the UCA International Users Group. This certificate shall only be reproduced in full and with the express permission of KETOP lab.

China KETOP Lab (Xuchang Ketop Testing Research Institute Co.,Ltd)
National Center For Quality Supervision & Testing of Relay Protection and Automation Equipment

1706#, Xuji Avenue, XuChang, Henan, P.R.China, P.C.461000
T +86 374 3212841 F +86 374 3212775 www.ketop.cn



Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version 3.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2 AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	AssN3, Srv6, Srv7, Srv8, Srv9, Srv10, SrvN1e, SrvN1f, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp9 RpN1, RpN2, RpN3, RpN4, RpN8	Rp5, Rp6,Rp7,Rp8, Rp11, Rp12, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br9, Br20, Br21, Br22, Br25, Br26, Br27, Br28 BrN1, BrN2, BrN3, BrN4, BrN5, BrN8	Br5, Br6,Br7,Br8, Br11, Br12
12a: Direct control	CtlN3, DOns1	DOns3
13: Time sync	Tm1, Tm2	Tm3,TmN1
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	

This certificate is issued in accordance with the laboratory accreditation requirements of the UCA International Users Group. This certificate shall only be reproduced in full and with the express permission of KETOP lab.