

# IEC 61850 Certificate Level A<sup>1</sup>

Page 1/2  
No. 19-001381-03-5

Issued to:  
YOUHO ELECTRIC IND.Co.,Ltd.  
39-42, Baekseok-eup, Yangju-si,  
Gyeonggi-do, Republic of Korea, 11517

For the server product:  
Substation Automation Local Information  
processing Device  
YH-SAS-LID  
Software Version 1.0  
Hardware : ADVANTECH ECU-4784 with  
Windows Server 2012 R2

Issued by: **Korea Testing Laboratory**

**The server product has not been shown to be non-conforming to:  
IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1  
Communication networks and systems in substations**

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.2, the product's protocol, model and technical issue implementation conformance statements: "YH-SAS-LID\_PICS\_v.1", "YH-SAS-LID\_MICS\_v.1", "YH-SAS-LID\_TICS\_v.1" and the extra information for testing: "YH-SAS-LID\_PIXIT\_v.1".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

|                                |                                  |
|--------------------------------|----------------------------------|
| 1 Basic Exchange (21/25)       | 9a GOOSE Publish (9/12)          |
| 2 Data Sets (3/6)              | 9b GOOSE Subscribe (10/11)       |
| 2+ Data Set Definition (24/24) | 12a Direct Control (5/11)        |
| 5 Unbuffered Reporting (18/18) | 12d Enhanced SBO Control (11/19) |
| 6 Buffered Reporting (25/27)   | 13 Time Synchronization (4/5)    |
|                                | 14 File Transfer (7/7)           |


This Certificate includes a summary of the test results as carried out at KTL in Republic of Korea with IEC 61850 KTL Testing Tool with test suite IEC 61850 Server Conformance Test V.1.0 and IEC 61850 KTL Trace Manager V.1.0. This document has been issued for information purposes only, and the original paper copy of the KTL report: No. TR-19-001381-03-5 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KTL by YOUHO ELECTRIC IND.Co.,Ltd.. The manufacturer's production process has not been assessed. This certificate does not imply that KTL has approved any product other than the specimen tested.

Seoul, Feb. 18, 2019



Ah Han  
Senior Engineer  
Research & Business Development Center



Jinyong Kim  
Principal Engineer  
Research & Business Development Center

1 Level A - Independent Test lab with accredited ISO/IEC 17025 Quality System

Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version 3.2.

| <b>Conformance Block</b>  | <b>Mandatory</b>  | <b>Conditional</b>   |
|---------------------------|---|--|
| 1: Basic Exchange         | Ass1, Ass2, Ass3, AssN2, AssN4, AssN5<br>Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd,<br>SrvN4  | AssN3, AssN6<br>Srv6, Srv7, Srv8, SrvN1e, SrvN1f,<br>SrvN2 |
| 2: Data Sets              | Dset1, Dset10a, DsetN1ae  |  |
| 2+: Data Set Definition   | Dset2, Dset3, Dset4, Dset5, Dset6, Dset7,<br>Dset8, Dset9<br>DsetN1cd, DsetN2, DsetN3, DsetN4,<br>DsetN5, DsetN6, DsetN7, DsetN8,<br>DsetN9, DsetN10, DsetN11, DsetN12,<br>DsetN13, DsetN14 | DsetN15a, DsetN15b   |
| 5: Unbuffered Reporting   | Rp1, Rp2, Rp3, Rp4, Rp9, RpN1, RpN2,<br>RpN3, RpN4, RpN8  | Rp5, Rp6, Rp7, Rp8, Rp10, Rp11,<br>Rp12, RpN5              |
| 6: Buffered Reporting     | Br1, Br2, Br3, Br4, Br9, Br20, Br21,<br>Br22, Br25, Br26, Br27, Br28<br>BrN1, BrN2, BrN3, BrN4, BrN5, BrN8  | Br5, Br6, Br7, Br8, Br10, Br11, Br12                       |
| 9a: GOOSE Publish         | Gop2, Gop3, Gop4, Gop9, Gop10a  | Gop1, Gop6, Gop7, GopN1                                    |
| 9b: GOOSE Subscribe       | Gos1a, Gos2, Gos3, GosN1, GosN2,<br>GosN3, GosN4, GosN5, GosN6  | Gos1b  |
| 12a: Direct Control       | CtlN3, DOns1  | Ctl2, CtlN11, DOns3  |
| 12d: Enhanced SBO Control | CtlN1, CtlN2, CtlN3, CtlN4, CtlN9<br>SBOes1, SBOes2, SBOes3   | Ctl2, Ctl3, CtlN11   |
| 13: Time Sync             | Tm1, Tm2  | TmN1, TmN2   |
| 14: File Transfer         | Ft1, Ft2ab, Ft4, FtN1ab   | Ft2c, Ft3, FtN1c   |